

C.L. "BUTCH" OTTER - Governor RICHARD M. ARMSTRONG - Director DEBBY RANSOM, R.N., R.H.I.T — Chief BUREAU OF FACILITY STANDARDS 3232 Elder Street P.O. Box 83720 Boise, Idaho 83720-0036 PHONE: (208) 334-6626 FAX: (208) 364-1888 E-mail: fsb@idhw.state.id.us

September 4, 2007

Jill Tyler, Administrator Brookside Landing 431 Johnson Avenue Orofino, ID 83544

License #: RC-680

Dear Ms. Tyler:

On June 21, 2007, a Fire Life Safety Survey was conducted at Brookside Landing. As a result of that survey, deficient practices were found. The deficiencies were cited at the following level(s):

• Non-core issues, which are described on the Punch List, and for which you have submitted evidence of resolution.

This office is accepting your submitted evidence of resolution.

Should you have questions, please contact Taylor Barkley, Health Facility Surveyor, Facility Fire, Safety, and Construction Program, at (208) 334-6626.

Sincerely,

TAYLOR BARKLEY

Health Facility Surveyor

Facility Fire Safety & Construction Program

TB/lj

c:

Mark Grimes, Supervisor, Facility Fire Safety & Construction Program



C.L. "BUTCH" OTTER, Governor RICHARD M. ARMSTRONG - Director DEBBY RANSOM, R.N., R.H.I.T - Chief BUREAU OF FACILITY STANDARDS 3232 Elder Street P.O. Box 83720 Boise, Idaho 83720-0036 PHONE: (208) 334-6626 FAX: (208) 364-1888 E-mail: fsb@idhw.state.id.us

July 2, 2007

Jill Tyler, Administrator Brookside Landing 431 Johnson Ave Orofino, ID 83544

Dear Ms. Tyler:

On June 21, 2007, a Fire Life Safety Survey was conducted at Brookside Landing. The facility was found to be providing a safe environment for its residents.

The enclosed form, stating no core issue deficiencies were cited during the survey, is for your records only and need not be returned.

Please bear in mind that non-core issue deficiencies were identified on the punch list, a copy of which was reviewed and left with you during the exit conference. The completed punch list form and accompanying evidence of resolution (e.g., receipts, pictures, policy updates, etc.) are to be submitted to this office by July 21, 2007.

Should you have any questions about our visit, please contact me at (208) 334-6626.

Sincerely,

MARK GRIMES

Supervisor

Facility Fire Safety & Construction Program

MG/slc

Enclosure

Bureau of Facility Standards STATEMENT OF DEFICIENCIES (X3) DATE SURVEY (X1) PROVIDER/SUPPLIER/CLIA (X2) MULTIPLE CONSTRUCTION AND PLAN OF CORRECTION COMPLETED **IDENTIFICATION NUMBER:** 01 - ENTIRE BUILDING A. BUILDING B. WING 13R680 06/21/2007 NAME OF PROVIDER OR SUPPLIER STREET ADDRESS, CITY, STATE, ZIP CODE **431 JOHNSON AVE BROOKSIDE LANDING** OROFINO, ID 83544 SUMMARY STATEMENT OF DEFICIENCIES PROVIDER'S PLAN OF CORRECTION (X4) ID (X5) COMPLETE DATE ID (EACH CORRECTIVE ACTION SHOULD BE (EACH DEFICIENCY MUST BE PRECEDED BY FULL PREFIX PREFIX REGULATORY OR LSC IDENTIFYING INFORMATION) CROSS-REFERENCED TO THE APPROPRIATE TAG TAG DEFICIENCY) R 000 Initial Comments R 000 The facility was found to be in substantial compliance with the fire and life safety requirements of the Rules for Residential or Assisted Living Facilities in Idaho. No core deficiencies were cited during the standard fire/life safety survey conducted on June 21, 2007. The surveyor conducting the survey was: Taylor Barkley Health Facility Surveyor Facility Fire safety & Construction

Bureau of Facility Standards

TITLE

(X6) DATE



## BUREAU OF FACILITY STANDARDS P.O. Box 83720 Boise, ID 83720-0036 (208) 334-6626 fax: (208) 364-1888

## ASSISTED LIVING Non-Core Issues Punch List

Facility Name			Physical Address	Phone Number		
BROOKSIDE LANGING Administrator			431 Johnson Aue	(208) 476 - 2000 ZHP Code'		
1 *			City	ZIP Code'	•	
Survey Team Leader			Orofino I)	83544		
Survey			Survey Type	Survey Date		
	SIDINA	BANKLEY		(6-2)	- NORMAN	
NON-CORE ISSUES						
ITEM #	RULE# 16.03.22	2000年1月1日 - 100日 - 100	DESCRIPTION		DATE RESOLVED	BFS USE
	415.05	The facility has not	had the sprinkler system			
•		Annually inspected.	•		8-24-7	
2	415.02	The Pacility has Not	had the fuel-fired heating d	<u>evices</u>		
		Annually inspected.			8-1-7	4 V (4) (8)
	404.01	The fire/snoke doors to the entrance of the				
		assisted side do not			7-19-7	
4	404.01	ond the hall by Room 28 do not work.				
	7	and the hall by Room	nd8 do not work.		8-8-7	
<u> </u>	404,01	the fire/smake de	oors by room 215 de not late	h when		
		Closcel.	,		7-19-7	3,30,191
						8 8 8
						6 6 6
	<u> </u>					819091
Response Required Date		Signature of Facility Representative			Date Signed	
7	21.7	1 JULIANI			16/21/	07